

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-1394:0112

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: APOLLO FIRE DETECTORS LTD 36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom
 Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754
 Email: clifton.gare-mogg@apollo-fire.co.uk

DESIGN: Series 65A Models 55000-138, -139, -140, -141, -142, -143, -144, -145, -146 combination electronic/fix temperature heat detectors. *Models 55000-139, -142, and -145 have the addition of a LED that flashes in the quiescent state. *Models 55000-138, -141, and -144 have the addition of a LED that flashes in the quiescent state and a magnet operated test switch. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Electrical: 9 - 33 VDC

55000-138, 55000-139, 55000-140: 1350 F
 55000-141, 55000-142, 55000-143: 1700 F
 55000-144, 55000-145, 55000-146: 2000 F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detectors for use with listee's separately listed compatible fire alarm control unit and listed *Series 65A Models 45681 Series detector bases (CSFM Listing No. 7300-1394:109) and *Series 60A Models 45681-200, -220, -232 and -251 detector bases (CSFM Listing No. 7300-1394:106). Refer to listee's Installation Instruction Manual for details.

Rev. 06-20-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO**, Program Coordinator
 Fire Engineering Division