

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7300-1394:0115 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom  
 Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754  
 Email: clifton.gare-mogg@apollo-fire.co.uk

**DESIGN:** XP95A Model 55000-750 isolator and 45681-211, \*45681-321 isolator bases. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as control unit accessories for use with separately listed compatible fire alarm control units. Model 55000-750 is only intended to be installed in the 4-wire redundant Style 7 of the Gamewell listed Models 620, 630, and 650 (CSFM Listing No. 7165-1288:144) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

Rev. 12-11-2007 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

*Listing Expires* **June 30, 2012**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
 Fire Engineering Division