

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7300-1394:0126 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom  
Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754  
Email: clifton.gare-mogg@apollo-fire.co.uk

**DESIGN:** XP95A Series Model 55000-790 Dual Switch Monitor Module and 55000-863 Relay Output Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 17 - 28 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

04-20-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

**Date Issued:** **July 01, 2011** *Listing Expires* **June 30, 2012**

**Authorized By:** *FRANCIS MATEO, Program Coordinator*  
*Fire Engineering Division*