



# FIRE DEPARTMENT

9 METROTECH CENTER

BROOKLYN, N.Y. 11201-3857

July 7, 2011

Della Barclay  
Conformance Administrator  
Apollo Fire Detectors Limited  
36 Brookside Road  
Havant  
Hampshire PO9 1JR  
United Kingdom

Re: Request for Certificate of Approval for XP95A and Discovery smoke, heat detectors, XP95A switch modules

Dear Ms. Barclay:

We acknowledge the receipt of your submission regarding the above referenced applications and the related fees (check #IBCWYKO4076531 for \$625 and check # IBCWYKO4076527 for \$50).

The fire alarm devices you submitted for approval (heat, smoke detectors and switch modules) do not require Certificate of Approval for use in NYC as per new Fire Code section FC 901.4.5. All these devices shall be listed by a Nationally Recognized Testing Laboratory (NRTL) in order to be installed in NYC as part of any fire alarm system.

Therefore, no further review is required and we are returning the application fees along with this letter.

Thank you.

Sincerely,

Shaji K. Joseph  
Deputy Director of Engineering  
Technology Management