

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7135-1394:0124 Page 1 of 1

**CATEGORY:** 7135 -- AUDIBLE DEVICES

**LISTEE:** APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom  
 Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754  
 Email: clifton.gare-mogg@apollo-fire.co.uk

**DESIGN:** Models 58000-011 and 58000-012 Discovery Open Area Sounder Beacons. Model 58000-011 is identical to Model 58000-012 except for the lens color. the beacon (visual part) is not intended for fire alarm use. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 17-28 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

08-05-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **August 08, 2011**

*Listing Expires* **June 30, 2012**

Authorized By: **MIKE TANAKA**, Program Coordinator  
 Fire Engineering Division