

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-1394:0123 Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: APOLLO FIRE DETECTORS LTD36 Brookside Rd, Havant, Hampshire, P09 1JR United Kingdom
Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754
Email: clifton.gare-mogg@apollo-fire.co.uk

DESIGN: Models 55000-041 and 55000-042 Intelligent Open Area Sounders. Model 55000-041 has a red housing and Model 55000-042 has a white housing. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 17-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

08-05-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **August 08, 2011** *Listing Expires* **June 30, 2012**

Authorized By: **MIKE TANAKA**, Program Coordinator
Fire Engineering Division