

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 5276-1394:0127 Page 1 of 1

CATEGORY: Carbon Monoxide Alarms

LISTEE: APOLLO FIRE DETECTORS LTD, 36 Brookside Rd, Havant, Hampshire, P09 1JR
 United Kingdom
 Contact: Clifton Gare-Mogg 44 (0) 23 9249 2412 Fax 44 (0) 23 9249 2754
 Email: clifton.gare-mogg@apollo-fire.co.uk

DESIGN: Model 51000-001 Single Station Carbon Monoxide Alarm with RF transmitter. It transmits RF signal to the local control panel Model 2GIG-CNTRL1-345. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3VDC; Battery replacement with Panasonic CR123A.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and ETL label.

APPROVAL: Listed as single station Carbon Monoxide alarm with RF transmitter for residential applications. For use with control panel Model 2GIG-CNTRL1-345 (CSFM listing number 7167-1738:0100). Refer to manufacturer's installation manual for details.

09-22-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **September 23, 2011**

Listing Expires **June 30, 2012**

Authorized By: **MIKE TANAKA**, Program Coordinator
 Fire Engineering Division