

Loss Prevention Certification Board



This is to certify

APOLLO FIRE DETECTORS LIMITED
36 Brookside Road, Havant, Hampshire PO9 1JR

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

XPA-OH-13032-APO Xpander photoelectric multisensor smoke detector
(refer to attached appendix for details)

which has complied with the requirements of the following:

EN 54-7: 2000 + A1: 2002 - Fire detection and fire alarm systems - Smoke detectors - Point detectors using scattered light, transmitted light or ionization

CEA 4021: 2003 - Specifications for fire detection and fire alarm systems Requirements and test methods for multisensor detectors, which respond to smoke and heat, and smoke detectors with more than one smoke sensor

Certificate No. 010ad

Issue No. 01

Date of Issue 11 January 2008

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: M McCullagh



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 8XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 010ad

APOLLO FIRE DETECTORS LIMITED

Products

LPCB Ref. No.

XPA-OH-13032-APO Xpander addressable radio linked photoelectric multisensor smoke detector (XPA-WB-10022-APO mounting base)

010ad/01

Notes:

1. *The complete radio base/detector combination is available as Apollo Part No.:*
 - XPA-CB-13032-APO
2. *The device must be used with the following batteries only:*
 - MN1500 LR6 - 1.5 volt alkaline AA cells
3. *The radio link functionality is not included within the scope of approval*

Bases

XPA-WB-10022-APO Radio link mounting base*

*Base manufactured by EMS

For details of Cross-Listed products and alternative branding please see pages 3 to 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: M McCullagh

Page 2 of 3

Date of Issue 11 January 2008

Issue No. 01

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 010ad

APOLLO FIRE DETECTORS LIMITED

ALTERNATIVE MODEL NUMBERS AND LABELLING

LPCB Ref. No.	Model No.	Alternative Model No.	Labelled	Distributors Cert
010ad/01	XPA-OH-13032-APO	XP-174-001	EMS	786c/01

For details of Cross-Listed products and alternative branding please see pages 3 to 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: M McCullagh

Page 3 of 3

Date of Issue 11 January 2008

Issue No. 01

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel: +44 (0)1923 664100
Fax: +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.