

Loss Prevention Certification Board



This is to certify

APOLLO FIRE DETECTORS LIMITED
36 Brookside Road, Havant, Hampshire PO9 1JR

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

55000-885 multisensor detector

(refer to attached appendix for details)

which has complied with the requirements of the following:

CEA 4021: 1999-06 - Specifications for fire detection and fire alarm systems - Requirements and test methods for multisensor detectors, which respond to smoke and heat, and smoke detectors with more than one smoke sensor

Certificate No. 010m

Issue No. 10

Date of Issue 28 November 2006

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 010m

APOLLO FIRE DETECTORS LIMITED

Products

55000-885 XP95 analogue addressable multisensor detector
(45681-209 and 45681-210 mounting base)¹

LPCB Ref. No.

010m/01

Note:

¹ Approved with Apollo XP95 and S90 digital communication protocols that have been configured for the XP95 multisensor detector in accordance with manufacturer's instructions.

Base

45681-209 XP95/Discovery standard deep mounting base
45681-210 XP95 mounting base

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN

Page 2 of 3

Date of Issue 28 November 2006

Issue No. 10

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 010m

APOLLO FIRE DETECTORS LIMITED

LPCB Ref No.	Model No.	Alternative Model No.	Labelled
010m/01	55000-885	ADR-885 23900-K130 55000-885 55000-885ADV DP951T	Olympia Electronics Kidde Context Plus Advanced Electronics Aritech
010	45681-210	23900-H05 45681-210 DB950	Kidde Context Plus Aritech
010	45681-209	EBI-12	ESMI

For details of Cross-Listed products and alternative branding please see page 3.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: E MATTIE-SULEIMAN

Page 3 of 3

Date of Issue 28 November 2006

Issue No. 10

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.